

Steve R. Owens

From: Steve R. Owens
Sent: Thursday, April 28, 2016 11:46 AM
To: permits@fayetttn.us
Subject: Arlington MH Park Reconnections

Mr. Pitner,

This correspondence is in regard to reconnections to the wastewater lagoon of residences that have burn down in the Arlington Mobil Home Park. We believe it's reasonable to assume that reconnecting a residence with the same expected flow rate (i.e., number of bedrooms) as the one that had burned would not cause the treatment facility to be further out of compliance.

Therefore, if you find it suitable, any request for reconnection to the wastewater lagoon within 90 days of a residence burning would be permissible to this office, provided the replacement residence will generate the same expected flow rate (i.e., number of bedrooms) as the one that had burned.

Any request for reconnection to the wastewater lagoon after 90 days may be evaluated on a case-by-case basis.

If you or your staff have any questions please do not hesitate to contact me.

Thank you,

Steve Owens
Environmental Consultant
Tennessee Department of Environment and Conservation
Office: (901) 371-3029
steve.r.owens@tn.gov



Tell us how we're doing!

Please take a few minutes to complete [TDEC's Customer Service Survey](#).